




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

NTPC-VINDHYACHAL:Frequency

National Grid Frequency Profile for

21-Oct-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.00	0.98	6.98	24.62	52.78	12.45	2.19	7.96	53.70	38.33	23.75	97.81	25.84

Average Frequency	50.03	Frequency Variation Index :	0.079	Standard Deviation :	0.085
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.31	16:04:30	Max	50.198	13:15:00
Min	49.70	18:13:10	Min	49.863	18:45:00

