




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

NTPC-VINDHYACHAL:Frequency

National Grid Frequency Profile for

23-Oct-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.00	0.00	2.81	21.60	53.81	19.14	2.64	2.81	50.19	47.00	25.32	97.36	23.61

Average Frequency		50.05	Frequency Variation Index :		0.082	Standard Deviation :		0.077
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.39	16:07:00	Max	50.317	16:15:00
Min	49.81	18:14:10	Min	49.904	5:45:00

