




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

DURGAPUR:Frequency

National Grid Frequency Profile for

24-Oct-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.08	0.88	8.03	38.88	42.45	8.82	0.86	8.99	64.14	26.86	17.22	99.06	29.06

Average Frequency	50.00	Frequency Variation Index :	0.062	Standard Deviation :	0.079
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.353	18:01:50	Max	50.161	16:15:00
Min	49.67	17:43:00	Min	49.864	18:00:00

