




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

RIHAND:Frequency

National Grid Frequency Profile for

25-Oct-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.00	0.71	9.55	35.24	40.90	11.72	1.88	10.25	58.67	31.08	18.18	98.13	28.39

Average Frequency	50.01	Frequency Variation Index :	0.076	Standard Deviation :	0.087
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.281	18:34:00	Max	50.169	13:15:00
Min	49.74	22:07:20	Min	49.815	9:30:00

