




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

RIHAND:Frequency

National Grid Frequency Profile for

26-Oct-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.00	0.76	5.73	33.44	43.53	14.75	1.79	6.49	57.78	35.73	19.94	98.21	26.63

Average Frequency	50.02	Frequency Variation Index :	0.074	Standard Deviation :	0.083
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.27	14:06:30	Max	50.204	22:00:00
Min	49.74	11:19:20	Min	49.856	11:30:00

