




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

NTPC-VINDHYACHAL:Frequency

National Grid Frequency Profile for

28-Oct-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.00	5.47	15.34	32.91	38.67	7.35	0.27	20.81	57.42	21.77	14.20	99.73	26.11

Average Frequency		49.98	Frequency Variation Index :		0.096	Standard Deviation :		0.095
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.226	0:02:00	Max	50.107	19:30:00
Min	49.71	12:19:20	Min	49.761	6:45:00

