




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

National Grid Frequency Profile for

29-Oct-14

NTPC-VINDHYACHAL:Frequency



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	1.04	4.10	13.52	44.02	32.78	4.27	0.28	18.66	64.87	16.47	12.00	98.68	26.99

Average Frequency	49.97	Frequency Variation Index :	0.092	Standard Deviation :	0.090
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.242	18:02:10	Max	50.115	10:15:00
Min	49.62	5:51:40	Min	49.715	6:00:00

