




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

VUJAYAWADA:Frequency

National Grid Frequency Profile for

03-Sep-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.79	4.02	18.37	40.14	32.26	3.78	0.65	23.17	61.22	15.61	11.62	98.56	29.69

Average Frequency	49.96	Frequency Variation Index :	0.101	Standard Deviation :	0.093
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.32	13:03:30	Max	50.222	13:15:00
Min	49.63	18:56:00	Min	49.756	19:00:00

