




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

VUJAYAWADA:Frequency

National Grid Frequency Profile for

07-Sep-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	1.10	4.87	15.31	44.31	31.03	3.38	0.00	21.28	64.48	14.24	11.13	98.90	29.87

Average Frequency	49.96	Frequency Variation Index :	0.096	Standard Deviation :	0.089
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.19	9:03:20	Max	50.090	16:15:00
Min	49.56	19:12:00	Min	49.703	19:15:00

