




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

MEERUT:Frequency

National Grid Frequency Profile for

10-Sep-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	2.20	7.84	20.24	35.12	30.59	4.02	0.00	30.28	55.08	14.64	10.82	97.80	25.45

Average Frequency	49.95	Frequency Variation Index :	3.032	Standard Deviation :	0.105
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.179	13:00:10	Max	50.104	13:00:00
Min	49.64	6:19:00	Min	49.708	5:00:00

