




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

NTPC-VINDHYACHAL:Frequency

National Grid Frequency Profile for

11-Sep-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.14	0.54	11.50	36.94	44.27	6.60	0.00	12.19	64.32	23.50	16.93	99.86	32.55

Average Frequency	49.99	Frequency Variation Index :	0.057	Standard Deviation :	0.075
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.182	0:00:50	Max	50.127	4:00:00
Min	49.62	18:43:20	Min	49.823	19:00:00

