




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

NTPC-VINDHYACHAL:Frequency

National Grid Frequency Profile for

14-Sep-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.00	0.63	7.01	33.22	46.00	11.46	1.69	7.64	57.38	34.98	21.89	98.31	25.12

Average Frequency	50.02	Frequency Variation Index :	0.071	Standard Deviation :	0.083
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.32	13:02:40	Max	50.253	17:15:00
Min	49.71	0:08:20	Min	49.845	1:45:00

