




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

NTPC-VINDHYACHAL:Frequency

National Grid Frequency Profile for

15-Sep-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.07	4.39	17.16	34.53	40.93	2.92	0.01	21.62	60.02	18.36	15.49	99.92	27.80

Average Frequency	49.97	Frequency Variation Index :	0.088	Standard Deviation :	0.089
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.2	17:02:30	Max	50.106	22:00:00
Min	49.69	18:54:50	Min	49.771	14:45:00

