




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

NTPC-VINDHYACHAL:Frequency

National Grid Frequency Profile for

16-Sep-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.45	5.59	22.51	37.30	31.00	2.56	0.59	28.55	57.52	13.92	10.81	98.96	24.70

Average Frequency	49.95	Frequency Variation Index :	0.110	Standard Deviation :	0.093
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.261	13:05:10	Max	50.130	13:15:00
Min	49.65	0:08:20	Min	49.784	0:15:00

