




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

DURGAPUR:Frequency

National Grid Frequency Profile for

17-Sep-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.00	0.98	12.12	46.69	34.93	4.69	0.59	13.10	65.50	21.40	16.16	99.41	26.13

Average Frequency		49.98	Frequency Variation Index :		0.064	Standard Deviation :		0.078
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.254	6:02:40	Max	50.138	8:00:00
Min	49.73	22:19:30	Min	49.829	22:30:00

