




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

DURGAPUR:Frequency

National Grid Frequency Profile for

19-Sep-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	1.90	6.08	29.32	37.64	23.11	1.84	0.12	37.29	52.95	9.76	7.80	97.99	19.63

Average Frequency	49.93	Frequency Variation Index :	0.138	Standard Deviation :	0.094
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.21	18:03:50	Max	50.067	18:30:00
Min	49.63	5:12:10	Min	49.706	5:00:00

