




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

NTPC-VINDHYACHAL:Frequency

National Grid Frequency Profile for

20-Sep-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.00	2.16	16.50	43.48	33.21	4.09	0.56	18.67	66.66	14.68	10.07	99.44	32.14

Average Frequency		49.97	Frequency Variation Index :		0.074	Standard Deviation :		0.082
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.324	18:03:30	Max	50.186	18:15:00
Min	49.72	14:43:50	Min	49.780	14:45:00

