




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

VIJAYAWADA:Frequency

National Grid Frequency Profile for

23-Sep-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	1.42	15.27	41.01	30.93	10.30	0.96	0.12	57.70	37.65	4.65	3.74	98.46	10.89

Average Frequency	49.89	Frequency Variation Index :	0.206	Standard Deviation :	0.090
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.218	6:03:30	Max	50.076	4:00:00
Min	49.62	0:06:50	Min	49.756	9:45:00

