




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

NTPC-VINDHYACHAL:Frequency

National Grid Frequency Profile for

24-Sep-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.00	0.78	11.48	36.89	40.29	8.99	1.57	12.26	60.96	26.78	16.27	98.43	27.80

Average Frequency	50.00	Frequency Variation Index :	0.073	Standard Deviation :	0.085
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.336	9:06:00	Max	50.239	9:15:00
Min	49.73	22:07:50	Min	49.843	5:00:00

