




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

NTPC-VINDHYACHAL:Frequency

National Grid Frequency Profile for

25-Sep-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.13	1.66	14.46	43.12	35.48	4.50	0.65	16.25	65.79	17.96	12.86	99.22	27.36

Average Frequency	49.98	Frequency Variation Index :	0.072	Standard Deviation :	0.082
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.277	6:04:40	Max	142.155	0:00:00
Min	49.68	18:43:00	Min	49.810	5:30:00

