




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

VIJAYAWADA:Frequency

National Grid Frequency Profile for

27-Sep-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	2.23	17.26	38.70	26.49	11.99	3.07	0.25	58.19	33.92	7.88	4.75	97.51	10.03

Average Frequency	49.89	Frequency Variation Index :	0.228	Standard Deviation :	0.103
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.26	18:03:40	Max	50.088	7:15:00
Min	49.64	0:22:10	Min	49.709	0:30:00

