




**POWER SYSTEM OPERATION CORPORATION LIMITED**  
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

DURGAPUR:Frequency

National Grid Frequency Profile for

27-May-16



<49.2	<49.7	<49.90	<49.97	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	49.90-50.05	49.7-50.2	49.97-50.03	50.05-50.1	>50	>50.03	>50.05	>50.2
0	0.01	19.10	54.55	1.52	17.57	52.87	26.02	2.01	72.29	99.99	29.81	6.62	28.01	15.64	8.61	0.00

<b>Average Frequency</b>	<b>49.96</b>	<b>Frequency Variation Index :</b>	<b>0.064</b>	<b>Standard Deviation :</b>	<b>0.070</b>
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency	
Max	50.18 18:03:30
Min	49.70 0:10:20

15 minute average Frequency		
Max	50.073	8:15:00
Min	49.817	14:45:00

No. of excursion above 50.03 Hz	83
No. of excursion below 49.97 Hz	161
No. of excursion above 50.00 Hz	122
No. of excursion below 50.00 Hz	120

Average time freq remains below 49.97 per excursion	0:04:53	Average time frequency remains above 50.03 per excursion	0:02:43
---	---------	--	---------