



National Load Despatch Centre  
राष्ट्रीय भार प्रेषण केंद्र  
GRID CONTROLLER OF INDIA LIMITED  
ग्रीड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)  
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016  
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: POSOCO/NLDC/SO/Daily PSP Report

दिनांक: 24<sup>th</sup> February 2023

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033  
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016  
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3-, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093  
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006  
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009  
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

**Sub: Daily PSP Report for the date 23.02.2023.**

महोदय/Dear Sir,

आईईजीसी-2010 की धारा स.-5.5.1 के प्रावधान के अनुसार, दिनांक 23- फ़रवरी-2023 की अखिल भारतीय प्रणाली की दैनिक ग्रीड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 5.5.1 of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 23<sup>rd</sup> February 2023, is available at the NLDC website.

धन्यवाद,

Report for previous day

Date of Reporting: 24-Feb-2023

**A. Power Supply Position at All India and Regional level**

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	49292	62200	47623	21606	2593	183314
Peak Shortage (MW)	1523	73	0	504	0	2100
Energy Met (MU)	1123	1473	1225	461	43	4325
Hydro Gen (MU)	137	71	80	29	10	327
Wind Gen (MU)	9	38	56	-	-	103
Solar Gen (MU)*	123.74	67.10	131.26	3.15	0.42	326
Energy Shortage (MU)	8.95	0.18	0.00	3.57	0.00	12.70
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	56661	68566	60853	22177	2668	207480
Time Of Maximum Demand Met (From NLDC SCADA)	10:13	10:14	10:54	18:18	18:05	10:14

**B. Frequency Profile (%)**

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.049	0.00	0.50	4.87	5.37	70.03	24.60

**C. Power Supply Position in States**

Region	States	Max.Demand Met during the day(MW)	Shortage during maximum Demand(MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	7503	0	155.8	750.3	0.0	256	0.00
	Haryana	7383	0	140.0	71.2	-0.7	141	0.29
	Rajasthan	16008	0	306.3	104.9	-1.2	204	7.88
	Delhi	3663	0	67.0	57.8	-3.2	76	0.00
	UP	16897	0	322.3	97.8	-0.3	254	0.13
	Uttarakhand	2016	70	38.8	26.5	0.2	97	0.49
	HP	1857	0	32.3	25.3	0.0	58	0.00
	J&K(UT) & Ladakh(UT)	2729	0	57.7	52.5	-1.6	92	0.16
	Chandigarh	209	0	3.3	3.4	-0.1	17	0.00
	Chhattisgarh	5175	80	116.0	62.8	0.4	224	0.18
WR	Gujarat	18567	0	409.6	194.0	2.9	778	0.00
	MP	14669	0	299.5	181.6	-3.4	275	0.00
	Maharashtra	28264	0	574.5	182.6	1.0	924	0.00
	Goa	688	0	14.2	13.7	0.3	57	0.00
	DNHDDPDCL	1278	0	28.9	29.2	-0.3	146	0.00
	AMNSIL	830	0	17.8	10.4	0.1	275	0.00
	BALCO	516	0	12.3	12.4	-0.1	514	0.00
	Andhra Pradesh	11748	0	228.0	80.5	-1.3	409	0.00
	Telangana	14526	0	289.6	165.8	-1.5	991	0.00
	Karnataka	15202	0	276.6	97.5	-2.2	744	0.00
SR	Kerala	4126	0	83.2	60.7	0.2	169	0.00
	Tamil Nadu	16370	0	338.3	199.3	-1.2	600	0.00
	Puducherry	413	0	9.0	8.9	-0.6	68	0.00
	Bihar	5005	112	90.1	84.6	-1.7	184	0.21
	DVC	3584	0	76.0	44.3	0.0	382	0.00
ER	Jharkhand	1484	70	25.9	22.7	-1.8	110	3.36
	Odisha	4980	0	111.5	25.0	-0.3	323	0.00
	West Bengal	7532	0	155.4	24.9	-3.1	55	0.00
	Sikkim	104	0	2.1	1.6	0.5	48	0.00
	Assam	1504	0	23.9	18.7	0.1	76	0.00
NER	Manipur	199	0	2.8	2.9	-0.2	15	0.00
	Meghalaya	371	0	6.6	6.2	-0.1	32	0.00
	Mizoram	117	0	1.6	1.6	-0.4	6	0.00
	Nagaland	132	0	2.2	2.2	-0.1	9	0.00
	Tripura	244	0	4.0	3.5	-0.2	33	0.00

**D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)**

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-1.9	-10.6	-23.2	0.2
Day Peak (MW)	-267.0	-490.2	-1070.0	16.0

**E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)**

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	145.3	-131.9	168.8	-177.1	-5.1	0.0
Actual(MU)	134.4	-116.7	162.6	-178.1	-7.2	-5.0
O/D/U/D(MU)	-10.9	15.3	-6.2	-1.1	-2.1	-5.0

**F. Generation Outage(MW)**

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	7201	15851	5008	1700	699	30458	49
State Sector	11550	12866	4361	2662	162	31600	51
Total	18750	28717	9369	4362	860	62058	100

**G. Sourcewise generation (Gross) (MU)**

	NR	WR	SR	ER	NER	All India	% Share
Coal	710	1461	703	691	17	3581	76
Lignite	31	14	66	0	0	111	2
Hydro	137	71	80	29	10	327	7
Nuclear	20	37	71	0	0	128	3
Gas, Naptha & Diesel	15	14	6	0	31	66	1
RES (Wind, Solar, Biomass & Others)	158	107	211	3	0	479	10
Total	1071	1703	1137	722	58	4692	100

Share of RES in total generation (%)	14.72	6.26	18.59	0.43	0.72	10.21
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	29.42	12.60	31.87	4.39	17.95	19.91

**H. All India Demand Diversity Factor**

Based on Regional Max Demands	1.017
Based on State Max Demands	1.041

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

\*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

\*\*Note: All generation MU figures are gross

\*\*\*Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve)/Export =(-ve) for NET (MU)  
Date of Reporting: 24-Feb-2023

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
<b>Import/Export of ER (With NR)</b>								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI-B/B	-	0	296	0.0	7.1	-7.1
3	765 kV	GAYA-VARANASI	2	0	642	0.0	13.2	-13.2
4	765 kV	SASARAM-FAITEHPUR	1	0	449	0.0	9.6	-9.6
5	765 kV	GAYA-BALIA	1	0	591	0.0	10.5	-10.5
6	400 kV	PUSAULI-VARANASI	1	0	175	0.0	3.8	-3.8
7	400 kV	PUSAULI-ALLAHABAD	1	0	180	0.0	3.3	-3.3
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	0	705	0.0	9.9	-9.9
9	400 kV	PATNA-BALIA	2	0	528	0.0	10.8	-10.8
10	400 kV	NAIBATTI-R-BALIA	2	0	560	0.0	11.6	-11.6
11	400 kV	BIHARSHARIFE-BALIA	2	0	264	0.0	3.5	-3.5
12	400 kV	MOTIHARI-GORAKHPUR	2	0	462	0.0	8.8	-8.8
13	400 kV	BIHARSHARIFE-VARANASI	2	0	402	0.0	7.8	-7.8
14	220 kV	SAHUPUR-BAKRAMANASA	1	0	117	0.0	1.7	-1.7
15	132 kV	NAGARUNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	25	0	0.5	0.0	0.5
17	132 kV	KARMANASA-SAHUPURI	1	0	49	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDALI	1	0	0	0.0	0.0	0.0
<b>ER-NR</b>						<b>0.5</b>	<b>101.5</b>	<b>-101.0</b>
<b>Import/Export of ER (With WR)</b>								
1	765 kV	JHARSUGUDA-DHARAMJIAGARH	4	921	291	5.0	0.0	5.0
2	765 kV	NEW RANCHI-DHARAMJIAGARH	2	151	721	0.0	8.0	-8.0
3	765 kV	JHARSUGUDA-DURG	2	0	773	0.0	13.8	-13.8
4	400 kV	JHARSUGUDA-RAIGARH	4	0	839	0.0	15.7	-15.7
5	400 kV	RANCHI-SIPA	2	0	323	0.0	4.7	-4.7
6	220 kV	BUDDHIPADAR-RAIGARH	1	0	207	0.0	3.8	-3.8
7	220 kV	BUDDHIPADAR-KORBA	2	4	123	0.0	1.2	-1.2
<b>ER-WR</b>						<b>5.0</b>	<b>47.3</b>	<b>-42.3</b>
<b>Import/Export of ER (With SR)</b>								
1	HVDC	JEYPORE-GAZIWAKA B/B	2	0	435	0.0	9.9	-9.9
2	HVDC	TALCHER-KOLAR BIPPLE	2	0	1985	0.0	41.1	-41.1
3	765 kV	ANGUL-SRIKAKULAM	2	0	2982	0.0	54.3	-54.3
4	400 kV	TALCHER-I/C	2	403	263	3.1	0.0	3.1
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
<b>ER-SR</b>						<b>0.0</b>	<b>105.3</b>	<b>-105.3</b>
<b>Import/Export of ER (With NER)</b>								
1	400 kV	BINAGURI-BONGAIGAOON	2	228	0	3.5	0.0	3.5
2	400 kV	ALIPURDUAR-BONGAIGAOON	2	780	0	13.6	0.0	13.6
3	220 kV	ALIPURDUAR-SALAKATI	2	81	0	1.4	0.0	1.4
<b>ER-NER</b>						<b>18.6</b>	<b>0.0</b>	<b>18.6</b>
<b>Import/Export of NER (With NR)</b>								
1	HVDC	BISWANATH CHARIALI-AGRA	2	484	0	11.6	0.0	11.6
<b>NER-NR</b>						<b>11.6</b>	<b>0.0</b>	<b>11.6</b>
<b>Import/Export of WR (With NR)</b>								
1	HVDC	CHAMPA-KURKSHETRA	2	0	1009	0.0	24.2	-24.2
2	HVDC	VINDHYACHAL-B/B	-	452	0	12.1	0.0	12.1
3	HVDC	MUNDRA-MOHINDERGARH	2	0	0	0.0	0.0	0.0
4	765 kV	GWALIOR-AGRA	2	18	1708	0.0	19.9	-19.9
5	765 kV	GWALIOR-PHAGI	2	0	1543	0.0	31.3	-31.3
6	765 kV	JABALPUR-ORAI	2	0	968	0.0	28.0	-28.0
7	765 kV	GWALIOR-ORAI	1	992	0	16.8	0.0	16.8
8	765 kV	SATNA-ORAI	1	0	916	0.0	17.4	-17.4
9	765 kV	BANASKANTHA-CHITORGARH	2	2095	0	36.0	0.0	36.0
10	765 kV	VINDHYACHAL-VARANASI	2	0	1893	0.0	19.4	-19.4
11	400 kV	ZERDA-KANKROLI	1	318	0	5.1	0.0	5.1
12	400 kV	ZERDA-BHINMAL	1	531	0	6.3	0.0	6.3
13	400 kV	VINDHYACHAL-RIHAND	1	486	0	11.0	0.0	11.0
14	400 kV	RAPS-SHILAIPTUR	2	391	0	408	2.9	-0.2
15	220 kV	BHANPURA-BANPUR	1	0	166	0.0	2.8	-2.8
16	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.3	-1.3
17	220 kV	MEHGAON-AURAIYA	1	99	0	1.2	0.0	1.2
18	220 kV	MALANPUR-AURAIYA	1	74	0	1.8	0.0	1.8
19	132 kV	GWALIOR-SAWALMADHOPUR	1	0	0	0.0	0.0	0.0
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
<b>WR-NR</b>						<b>92.3</b>	<b>146.6</b>	<b>-54.4</b>
<b>Import/Export of WR (With SR)</b>								
1	HVDC	BHADRAWATI-B/B	-	0	1012	0.0	13.2	-13.2
2	HVDC	BAHARH-PUGAUR	2	0	4010	0.0	56.6	-56.6
3	765 kV	KOLHAPUR-KACHHUP	2	650	1284	1.2	9.5	-8.3
4	765 kV	WARDHA-NIZAMABAD	2	0	3147	0.0	52.8	-52.8
5	400 kV	KOLHAPUR-KUDGI	2	1321	0	23.8	0.0	23.8
6	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
7	220 kV	BONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
8	220 kV	NELDEMI-AMBEWADI	1	0	136	2.4	0.0	2.4
<b>WR-SR</b>						<b>27.5</b>	<b>132.0</b>	<b>-104.6</b>
<b>INTERNATIONAL EXCHANGES</b>								
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	Import(+ve)/Export(-ve)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHHU IEP 4180MW)	0	0	0	-1.83		
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA IEP 6170MW)	179	0	61	1.61		
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA IEP 4584MW)	0	0	0	-2.29		
	NER	132kV GELEPHU-SALAKATI	30	15	23	0.55		
NEPAL	NER	132kV MOTANGA-RANGIA	24	0	1	0.03		
	ER	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	0	0	0	0.00		
BANGLADESH	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-345	-136	-317	-7.60		
	ER	BHERAMARA B/B HVDC (B'DESH)	-918	-744	-840	-20.16		
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	16	0	7	0.16		
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-152	0	-127	-3.04		